



- NOTE:
1. ALL OTHER PORTS PRESSURIZED.
  2. ALL VALVES NORMALLY OPEN, PRESSURE TO CLOSE.
  3. DRAIN LINE FLOW CONTROLLER NOT SHOWN.

PRINTED IN U.S.A.

SERIES 58B-TB STAGER PROGRAM

NOTCH	POS.	FUNCTION		PORTS VENTED (NOTE 1)	VALVES OPEN	NOTCH	POS.	FUNCTION		PORTS VENTED (NOTE 1)	VALVES OPEN
		UNIT A	UNIT B					UNIT A	UNIT B		
A	0*	SERVICE	STANDBY	6,14,16	21,11,12	J	5*	STANDBY	SERVICE	6,8,14	21,22,11
B						K					
C						L					
D	1	BACKWASH	SERVICE	1,2,6,8	13,14,21,22	M	6	SERVICE	BACKWASH	9,10,14,16	23,24,11,12
E						N					
F	2**	BRINE DRAW	SERVICE	4,5,6,8	15,16,21,22	P	7**	SERVICE	BRINE DRAW	12,13,14,16	25,26,11,12
G	3	SLOW RINSE	SERVICE	4,5,6,8	15,16,21,22	Q	8	SERVICE	SLOW RINSE	12,13,14,16	25,26,11,12
H	4	FAST RINSE	SERVICE	5,6,8,14	16,21,22,11	R	9	SERVICE	FAST RINSE	6,13,14,16	21,26,11,12

\* - NOTCH LOCATION FOR 1ST AUX. CAM/SWITCH

\*\* - NOTCH LOCATION FOR 2ND AUX. CAM/SWITCH

A	INITIAL RELEASE	NONE	JWB	31JUL01
REV	DESCRIPTION	ECO	DWN	DATE APVD

**AQmatic** 16605 West Victor Rd  
New Berlin, WI 53151  
262-326-0100  
www.aq-matic.com

**TWO UNIT ALTERNATING  
SOFTENER W/ TIMED BRINE**

SCALE N/A	DRAWN JWB	DATE 31JUL01	DWG. NO. 1078294
--------------	--------------	-----------------	---------------------